

**WARREN TOWNSHIP SEWERAGE AUTHORITY****RESOLUTION NO. 14-41****RESOLUTION GRANTING PRELIMINARY AND FINAL APPROVAL OF THE APPLICATION OF JOHN GESCHWINDNER FOR SINGLE CONNECTION AND ONE (1) EDU OF CAPACITY TO SERVE AN EXISTING SINGLE-FAMILY DWELLING LOCATED AT 10 THIRD STREET, BLOCK 12, LOT 20 IN THE STAGE V SERVICE AREA**

**WHEREAS**, the applicant, John Geschwindner, has applied to the Authority for preliminary and final approval for a connection by means of a 4-inch gravity lateral with one (1) EDU of capacity to serve an existing single-family dwelling on Block 12, Lot 20, located at 10 Third Street, in the Stage V sewer service area; and

**WHEREAS**, the applicant proposes 28 LF of 4-inch lateral SDR 35 PVC piping within the right of way and a saddle tap connection and into the existing 8-inch sanitary sewer in Elm Avenue; and

**WHEREAS**, the Authority's Engineer, by memorandum dated April 1, 2014, has indicated that he has reviewed the February 4, 2014 plans and drawings, last revised March 28, 2014, submitted on behalf of the applicant, and has determined that this connection was designed in accordance with the Authority's Rules and Regulations and has recommended that the Authority grant preliminary and final approval.

**NOW, THEREFORE, BE IT RESOLVED**, by the Warren Township Sewerage Authority in the County of Somerset, New Jersey that the Authority hereby grants preliminary and final approval to John Geschwindner for a connection by means of a 4-inch gravity lateral with one (1) EDU of capacity to serve an existing single-family dwelling on Block 12, Lot 20, located at 10 Third Street, in the Stage V sewer service area. The approval granted herein is subject on the following conditions:

1. The applicant shall comply with all of the Authority's Rules and Regulations, and the payment of all fees, including the payment to the Authority of the then applicable connection fees.
2. The applicant shall comply with the local Plumbing Sub-code Official regarding the new sanitary sewer construction on the subject parcel.
3. The installation of the saddle tap and the 28 LF of 4-inch lateral piping within the Elm Avenue right-of-way is under the jurisdiction of the Authority and must be inspected by a representative of the Authority. In accordance with the Authority's Rules and Regulations, and after consultation with the Authority's Engineer, the applicant must pay an additional escrow amount of \$560.00.
4. The applicant shall properly abandon the existing septic system once connection to the Authority's sewer system has been made.
5. The applicant shall not commence any construction without first obtaining the necessary permits, including a County and/or Township Road Opening Permit for work performed within Elm Avenue.
6. If applicable, the applicant prior to any excavation must provide written notice to the Somerset-Union Soil Conservation District.
7. The Applicant shall complete all site restoration work associated with the construction of the sanitary sewer to the satisfaction of the Authority and the Township.
8. The applicant shall not commence any construction requiring engineering inspection until it has provided proof to the Authority that the applicant has notified the "One-Call Damage Prevention System" pursuant to the Underground Facility Protection Act, N.J.S.A. 48:2-73, et seq., which proof shall be provided by supplying the Authority with the confirmation

{00447688.1}


number assigned to the notice of intent pursuant to said Act.

Moved by Mrs. Garafola  
Seconded by Mr. Vetter

Roll Call Vote	Yes	No
Chairman Truglio	x _____	_____
Mr. Mosquera	_____	_____
Ms. Garafola	x _____	_____
Mr. Vetter	x _____	_____
Mr. Reeder	_____	_____
Mr. Checchio (Alt 1)	_____	_____
Mr. Paoella (Alt 2)	_____	_____

**CERTIFICATION**

I, Deborah Catapano, Secretary of the Warren Township Sewerage Authority in the County of Somerset, New Jersey, do hereby certify that the above resolution is a true and correct copy of a resolution adopted at a meeting of the Warren Township Sewerage Authority on April 16, 2014.

  
 \_\_\_\_\_  
 Deborah Catapano, Authority Secretary